



## ~70% of new global generation capacity will be renewable

#### **Total Installed Capacity '18**



#### **Total Installed Capacity '30**



- Wind & Solar are the cheapest source of energy for 2/3 of the world, renewable penetration will continue to increase
- Gas, steam and nuclear still prevalent in '30, with 4,600 GW installed capacity
- Hybrid systems integrating storage (BESS, PSP) can provide improved dispatchability, grid stability & efficiency



### WHY ENERGY STORAGE?

A battery energy storage solution offers new application flexibility and unlocks new business value across the energy value chain.

Energy storage supports diverse applications including firming renewable production, stabilizing the electrical grid, controlling energy flow, optimizing asset operation and creating new revenue by delivering:



#### **Active Power Services**


- Frequency regulation
- Frequency response
- Peak shaving/firming
- Remote power commands
- Ramp rate control
- Curtailment avoidance
- Scheduled dispatch/shifting

- Scheduled power commands
- State of charge management
- Islanding
- Black start



#### **Reactive Power Services**

- Voltage control
- Voltage droop
- Power factor control
- VAR control



### **ENERGY STORAGE: UNPRECEDENTED FLEXIBILITY IN GRID**

**OPTIMIZATION** 

1 Baseload cause renewables to be curtailed
Energy Storage is charged with free or negative priced
energy


Peak Load
Energy Storage is discharged during peak demand periods

3 Spinning Reserve

Energy Storage discharges during dynamic events (clouds)


4 Frequency Regulation


Energy Storage continuously charges and discharges to maintain grid stability



### Energy Storage Market

Energy – "2 to 6 Hours" Mid Power – "1 Hour" High Power "30 Minute"








## Energy Storage ... Select competitors

# **AES**"Utility System"



**Leading utility scale** ... 116MW, integrate @ wind, GT's + stand alone

**Tech leadership...** source battery, own controls + integration + dev't

**Global reach...** installs in US, LATAM, EU, India; MHI partner to reach Asia

Turnkey utility solution with scale

#### Tesla

"EVs + residential storage"



**Scale from EV to Resi**... leverage scale, partner w/ Solar city

**Gigafactory** ... \$5B, 50GW/yr battery packs, 5.8MM sqft

Challenging economics... ~\$.3/kWh, including installation & PV charging

Creating substantial "buzz" but costs must fall for scale

### Sonnen

"C&I Storage platform"



**10K batteries shipped...** German dereg mkt, expanding to US/Aus


**Energy trading platform...** bypass utility, \$.23/kWh (20% saving)

**Select opportunities** ... Hawaii 4kWh @ \$10K, ~6.5yr payback

Platform & product to enable grid defection



### Storage solutions provider value chain





### Different needs drive different storage applications

#### **Captive Generation**



- Large industrial consumers to maximize self consumption
- Replacement of more expensive captive thermal generation
- Matching specific load requirements

# Dispatchable peak power solutions

y magazine India May 9, 2020

Renew Power wins 400MW "round-the-clock" renewables auction at Rs2.90/KWh

The developer can opt for solar, wind or a hybrid facility alongside an energy storage system to ensure 24hour power supply

- SECI 1.2GW tender for guaranteed peak power supply
- Bid must have 1
   renewable asset
   component & 1 storage
   component
- Two-part tariffs: Peak Tariff & OffPeak Tariff

#### **Thermal Hybrids**



- Coupling older aged gas units with storage to enhance peakers
- Thermal hybrids with larger array of grid services being feasible
- CO2 improvements & lower OPEX on gas units

#### Island grid - stability



- Weaker grids / island grids with power quality issues as renewables penetration rises
- Several island grids requiring mandatory coupling of storage with renewables



# Captive Generation – a Case Study

#### **CUSTOMER CHALLENGE**


- Matching a specific load profile (highenergy consuming Cement plant)
- Reduce transmission charges
- Interconnect limited to 25MWs of capacity

#### PROJECT DESCRIPTION

- 17.5 MW Wind, 25 MW solar AC and 20MWH/5MW battery – particular to shift MWHs to most expensive peak hrs
- Integrated control system

#### **APPROACH**

- Analyze best technical and economic hybrid system
- Design controls and optimization architecture



LCOE Thermal: \$c 5.0/kwH LCOE Hybrid: \$c 4.2/kwH

#### **BUSINESS CASE**

- ~12 pts. of CF increase
- Savings on substation
- 7.5MWs of inverters and unit transformers removed
- ~Avoided transmission charges, reduced OPEX and cost of night charging for solar plant



# Dispatchable peak power – a Case Study

#### **CUSTOMER CHALLENGE**

SECI requirements (1st 10 years):

- >40% plant CUF
- >85% of 50MWac output during peak hours.
- >50% of POI = Storage power rating
- PV + BESS or Wind + PV + BESS

#### PROJECT DESCRIPTION


- 50MWac Solar + 140MW Wind + 50MW/150MWh BESS
- DC/AC ratio up to 2.2 for higher CUF

#### **APPROACH**

- Determine ideal mix between PV+BESS,Wind + BESS or PV+Wind+BESS
- Optimize for CUF compliance and lowest LCOE during peak period

	Annual Plant CUF				Monthly Average Output (MW) in Peak Hours								
Year	%	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1	53.4%	55.7	63.6	59.9	55.4	66.1	78.4	92.2	84.6	61.7	43.7	50.9	4
2	53.3%	55.1	63.4	59.8	55.2	65.9	78.3	92.2	84.5	61.6	43.5	50.8	4
3	53.2%	55.0	63.2	59.6	55.0	65.8	78.2	92.1	84.4	61.4	43.4	50.6	4
4	53.1%	54.8	63.0	60.0	55.6	66.1	78.5	92.2	84.6	61.8	43.6	51.1	4
5	52.9%	55.4	63.8	60.1	55.5	66.0	78.5	92.1	84.6	61.7	43.5	51.0	- 4
6	52.8%	55.2	63.6	59.9	55.3	65.9	78.4	92.1	84.5	61.6	43.3	50.9	4
7	52.7%	55.1	63.4	59.7	55.2	65.8	78.3	92.1	84.5	61.5	43.2	50.8	4
8	52.5%	55.6	64.2	60.4	55.7	66.0	78.5	92.1	84.6	61.8	43.5	51.1	
9	52.4%	55.5	64.0	60.3	55.5	65.9	78.5	92.1	84.6	61.7	43.4	50.9	-
10	52.3%	55.3	63.9	60.1	55.4	65.8	78.4	92.1	84.5	61.6	43.3	50.8	
11	52.2%	55.2	63.7	59.9	55.2	65.7	78.3	92.1	84.5	61.5	43.3	51.1	
12	52.0%	55.7	64.5	60.6	55.7	66.0	78.5	92.1	84.6	61.9	43.3	51.0	-
13	51.8%	55.6	64.3	60.4	55.5	65.9	78.4	92.0	84.6	61.8	43.2	50.9	
14	51.7%	55.5	64.2	60.3	55.4	65.7	78.4	92.0	84.5	61.7	43.1	50.8	
15	51.7%	55.3	64.1	60.1	55.2	65.6	78.3	92.0	84.5	61.8	43.3	50.9	-
16	51.4%	55.7	64.7	60.8	55.6	65.9	78.4	92.0	84.5	61.9	43.1	50.8	
17	51.3%	55.6	64.5	60.6	55.5	65.8	78.4	92.0	84.5	61.8	43.0	50.7	
18	51.3%	55.5	64.4	60.5	55.3	65.7	78.3	92.0	84.4	61.7	42.9	50.6	-
19	51.1%	55.4	64.3	60.3	55.2	65.6	78.3	92.0	84.4	61.9	43.0	50.7	-
20	50.9%	55.7	64.8	60.9	55.6	65.7	78.4	92.0	84.4	61.8	42.9	50.6	-
21	50.8%	55.6	64.7	60.7	55.4	65.6	78.3	91.9	84.4	61.7	42.8	50.6	-
22	50.7%	55.5	64.6	60.6	55.3	65.5	78.3	91.9	84.3	61.6	42.7	50.5	-
23	50.6%	55.3	64.4	60.4	55.2	65.4	78.2	91.9	84.3	61.7	42.7	50.5	-
24	50.4%	55.7	64.9	60.9	55.4	65.5	78.3	91.9	84.3	61.6	42.6	50.4	-
25	50.3%	55.5	64.8	60.8	55.3	65.4	78.3	91.9	84.3	61.5	42.5	50.3	





#### **BUSINESS CASE**

- >62% Year 1 CUF room for non-compliance
- Peak compliance annual40% the entire year
- PV+Wind+BESS solution most ideal in terms of annual CUF and LCOE/tariff
- Peak Tariff for 14%
   equity hurdle rate
   (\$/MWh) \$89.6/MWh
   (6.5 Rs /kWh) < current</li>
   baseload facilities



# Thermal Hybrids – a Case Study

#### **CUSTOMER CHALLENGE**

- Reducing system energy costs on aged gas units
- CO2 footprint reduction while providing same level of ancillary services (spinning reserves, PFR) to the grid

#### PROJECT DESCRIPTION

- LM6000 GT retrofitted with 10 MW / 4.3
   MWh Li-Ion battery storage system
- Integrated control system

#### **APPROACH**

- Analyze best technical and economic sizing of the storage system
- Design controls and optimization architecture between gas unit and storage system



#### **BUSINESS CASE**

- Emissions reduced by 60%
- Two million gallons of water saved annually
- Increased dispatch rate
- >\$250k reduction in annual lifecycle costs\*
- GHG emissions
   reduction CAISO
   \$59k/yr
- Improved grid stability
   for new customers



## Island grid stability – a Case Study


#### **CUSTOMER CHALLENGE**

- Strict ramp requirements from Hokkaido Electric in order to grant 63MW Wind Project grid Interconnection:
  - i. Ramp < +/-1%/min at all times
  - ii. 4 blocks of day

Time of Day	7:00 –	11:30 -	16:00 -	20:00 -	
	10:00	13:30	19:00	23:00	
Requirement	No decrease	Maintain	No decrease	No increase	

#### **APPROACH**

- Analyze best technical and economic hybrid system that meets HEPCO compliance
- Battery sized to minimize CAPEX & curtailment while achieving grid compliance



#### **Business Case**

- Decision had to be made on pursuing onsite storage vs. upgrading grid network to secure grid connection
- Unclarity on non-compliance penalties made storage case unviable/unpredictable as 100% compliance significantly increased storage CAPEX; technically 100% compliance was achievable



### GE Renewable Energy

### \$15B revenue • 40,000 employees


















Broadest portfolio in the industry; gives us scale, scope and capability to fulfill our mission